




## STATE OF WASHINGTON DEPARTMENT OF ECOLOGY

3100 Port of Benton Blvd • Richland, WA 99352 • (509) 372-7950

June 28, 2006

Mr. Don L. Flyckt, Manager Liquid Processing and Container Storage Fluor Hanford P.O. Box 1000, MSIN: S5-31 Richland, WA 99352



EDMC

Re: Site Visit of the 200 Area Effluent Treatment Facility (ETF) and Technical Assistance Report by the Department of Ecology

Dear Mr. Flyckt:

The Department of Ecology appreciates the time you and your staff spent with us May 11, 2006, during our Technical Assistance Visit and Site Tour of the 200 Area ETF. It provided valuable technical assistance to our newly assigned engineer, Michelle Mandis. Ecology noted that the ETF looked clean and very well maintained. All systems (rough filter, UV-oxidizer, pH adjustment, hydrogen peroxide decomposer, fine filter, degasification column, reverse osmosis membranes, ion-exchange columns, distillate flash tank, heater, vapor compressor, evaporator, thin film dryer, powder hopper, and packaging components) were in stand-by mode with active surveillance on the floor and in the Operations Control Room. Ecology has provided a copy of the site visit notes as an enclosure in this letter.

Before the facility tour, the following piping modifications were discussed:

- Replacing the Liquid Effluent Retention Facility (LERF) return hose line with hard-piping (stainless steel).
- Installation of a stainless steel line in ETF for direct feed into the Secondary Waste Receiving Tank (SWRT). This line will also serve as a recycle line from the LERF Wastewater Feed stream to SWRT in the Secondary Treatment Train passing through the influent filter. (Thus allowing a larger amount of dissolved solids to be removed before the wastewater is sent though the Reverse Osmosis unit in the Main Treatment Train.)

Fluor Hanford (FH) provided a drawing adding a preliminary mark-up of the upcoming piping modifications as indicated in the enclosure. FH then identified to Ecology the physical location of the upcoming piping modifications during the walk down of the facility.

Also discussed during the site visit, was the planned addition of a new solidification treatment unit (STU) which will grout the solids and supplement the Thin Film Dryer. Ecology noted that before the installation and operation of the STU and in accordance with Washington

Mr. Don Flyckt June 27, 2006 Page 2

Administrative Code (WAC) 173-240-110, submission and approval of an engineering report, plans and specifications, and submission of the operations and maintenance manual were required (which is defined as the three-step process). Ecology indicated to the Permittee this three-step process could be waived in lieu of conceptual plans per WAC 172-240-110 (5). The Permittee has made this request, and therefore, Ecology agrees to waive the three step process. Ecology provided guidance for the content of the engineering submittal and sent an example report to the facility via email.

If you have any questions, contact me at 509-372-7890.

Sincerely,

Kathy Conaway

Facility Manager

Nuclear Waste Program

Kathy Conaway

pll

Enclosures (2)

cc w/enc:

Nick Ceto, EPA

Mark French, USDOE

Joel Hebdon, USDOE

Oscar Holgado, USDOE

Mary Jarvis, USDOE

Ed Macalister, USDOE

Matthew McCormick, USDOE

Larry Romine, USDOE

Sally Sieracki, USDOE

Raja Ranade, FH

Roger Szelmeczka, FH

Brent Barnett, PNNL

Stuart Harris, CTUIR

Gabriel Bohnee, NPT

Russell Jim. YN

Administrative Record: State Waste Discharge Permit ST-4500

Environmental Portal



## STATE OF WASHINGTON DEPARTMENT OF ECOLOGY WATER COMPLIANCE INSPECTION REPORT

substitute for OMB No. 2040-0057 and EPA form 3560-3 (Rev. 9-94) (last file update 12-95)

FACILITY NAME:ETI	<del>?</del>	
FACILITY NUMBER:S	Γ-4500	
SECTION 1: INSPECTION INFORMATION		
START DATE: <u>5/11/06</u>	PRIMARY INSPECTOR	M,MANDIS
INSPECTION TYPE (CHECK ONE):	PERMIT#	ST-4500
COMPLIANCE INSPECTION W/O SAMPLING	COMPLAINT #	
COMPLIANCE INSPECTION W/ SAMPLING COVERAGE INSPECTION	LAB PROJECT # ENFORCEMENT DOCKET #	
COMPLIANCE FOLLOW-UP INSPECTION	Y/N:	
TECHNICAL ASSISTANCE VIST FOR X	Scheduled	Y
ECOLOGY	ANNOUNCED	Y
OPERATION & MAINTENANCE INSPECTION	PART OF A GROUP	Y
REASON FOR INSPECTION	F	AC. REP
(CHECK ONE) PARTICIPANTS	AGENCY	(Y/N) PHONE #
ROUTINE <u>R.Szelmeczka</u>	<u> </u>	<u>Y 373-4200</u>
COMPLAINT KLUECK	<u>FHI</u> FHI	Y 372-3652 Y 372-9505
DRIVE BY B.PAVLINA D.FLYCKT	FHI =	Y 372-3142
QA K.CONAWAY	ECY	N 372-7890
BIO-MONITORING B.DERRICK	<u>ECY</u>	N 372-7896
OTHER (SPECIFY) X <u>M.MANDIS</u>	<u>ECY</u>	<u>N</u> <u>372-7970</u>
FAMILIARIZE W/ FACILITY	d <sup>a</sup>	
1 ACILI1 1		
SECTION 2: FACILITY INFORMATION	SECTION 3: AREAS EVALU	ATED DURING INSPECTION
FACILITY: ETF	N = NOT EVALUATED, $S = SA$	TISFACTORY
NAME: EFFLUENT TREATMENT FAC.	M = MARGINAL, Ú = UN	
ADDRESS: HANFORD	,	
<u>DATE</u> <u>TIME</u>	INSPECT BENCH SHEETS	<del></del> .
	INSPECT PERMIT	· .
ENTRY 1 <u>5/11/06</u> <u>9:20 AM</u> EXIT 1 5/11/06 11:40 AM	RECORDS/REPORTS FLOW MEASUREMENTS	
EXIT 1 <u>5/11/06</u> <b>11:40 AM</b>	LABORATORY	<u>≥</u>
ENTRY 2	EFFLUENT/RECEIVING WATER	
EXIT 2	<u> </u>	•
ENTRY 3	PRE-TREATMENT COMPLIANCE SCHEDULES	<del>= 1</del>
EXIT 3	SELF MONITORING PROGRAM	≥
ENTRY TYPE	OPERATION & MAINTENANCE	<u>~</u>
(CHECK ONE)	SLUDGE DISPOSAI	
DENY	FACILITY SITE REVIEW	<del></del>
DELAY	LAB ACCREDITATION	<u>N</u>
Warrant	OTHER (SPECIFY	) <u>N</u>
REGULAR X		

SEE ATTACHED NOTES.				.
BES ATTACLES NOTES.	•			
		•		
·	· .			i
,			,	
		•		
			•	
	•			
	•			
		. *	•	
		*	× .	
				,
·				
CTION 5: FOLLOW-UP (CHECK ALL TH				
Туре	DETAIL	RESP. PERSON	SCHEDULE	DONE
CONDUCT CLASS II				
LAB ACCRED MANUAL				
RE-INSPECT			<u> </u>	
RE-OPEN PERMIT	<u> </u>	·		
SEND APPLICATION	<u></u>	<u> </u>		
X TECH ASSIST-REGULAR	DETERMINE TYPE OF ENGR	K.CONAWAY/	<u>6/06</u>	5/06
TECH ASSIST-OUTREACH	REQUIREMENT FOR STU	M.MANDIS	•	
MOD PERMIT AT RENEWAL				
X FACILITY ACTION	ENGR MEMO & DWG	R.SZELMECZKA	<u>8/06</u>	<u>IN</u>
ENFORCEMENT (WARN LET	REQUIRED FOR STU			<u>Prog</u>
Nov, Order, Penalty)				5/31/04
X OTHER (SPECIFY)	<u>UPDATE PERMIT APP</u>	R.SZELMECZKA	<u>8/06</u>	<u>IN</u>
W WALL ASSAULE ENCIR'S	Ecology affroid fermit	-14191 W supplement	al info	PROG
(Completed task)	- 42 11	A - 4 8 8 4	• U •	5 12m 3 N/ B
(COMPURATOR)	₹ ₽			UIIZ JUU
(COMPURATUR)				Ce112/04
	* #			<u> </u>
CTION 6: ACTIVITIES (CHECK ALL THA	AT APPLY)			(112)04 
CCTION 6: ACTIVITIES (CHECK ALL THE DESCRIPTION	* #	TRACKING NUMBE	R	(1/2/04 
CTION 6: ACTIVITIES (CHECK ALL THE DESCRIPTION  DATA RECEIVED FROM LAB	AT APPLY)  DATE COMPLETE	TRACKING NUMBE	R	Ce[12]0C
CTION 6: ACTIVITIES (CHECK ALL THE DESCRIPTION  DATA RECEIVED FROM LAB  DRAFT INSPECTION REPORT COM	AT APPLY)  DATE COMPLETE  PLETED	TRACKING NUMBE	R	<u> </u>
CTION 6: ACTIVITIES (CHECK ALL THE DESCRIPTION  DATA RECEIVED FROM LAB  DRAFT INSPECTION REPORT COME	DATE COMPLETED PLETED PLETED	O TRACKING NUMBE	R	<u> </u>
DESCRIPTION  DATA RECEIVED FROM LAB  DRAFT INSPECTION REPORT COME FINAL INSPECTION REPORT COME FINAL INSPECTION REPORT REPORT COME	DATE COMPLETED PLETED PLETED	TRACKING NUMBE	R	<u> </u>
CCTION 6: ACTIVITIES (CHECK ALL THE DESCRIPTION  DATA RECEIVED FROM LAB  DRAFT INSPECTION REPORT COME FINAL INSPECTION RPT RCD FROM FORM 3506 SENT TO EPA	DATE COMPLETED PLETED PLETED	TRACKING NUMBE	R	<u> </u>
DESCRIPTION  DATA RECEIVED FROM LAB  DRAFT INSPECTION REPORT COM FINAL INSPECTION REPORT COM FINAL INSPECTION RPT RCD FROM FORM 3506 SENT TO EPA INSPECTION REPORT REVIEWED	DATE COMPLETED PLETED PLETED	D TRACKING NUMBE	R	<u> </u>
DESCRIPTION  DATA RECEIVED FROM LAB  DRAFT INSPECTION REPORT COME  FINAL INSPECTION REPORT COME  FINAL INSPECTION RPT RCD FROM  FORM 3506 SENT TO EPA  INSPECTION REPORT REVIEWED  SAMPLES TO LAB	DATE COMPLETED PLETED PLETED	O TRACKING NUMBE		
DESCRIPTION  DATA RECEIVED FROM LAB  DRAFT INSPECTION REPORT COM FINAL INSPECTION REPORT COM FINAL INSPECTION RPT RCD FROM FORM 3506 SENT TO EPA INSPECTION REPORT REVIEWED	DATE COMPLETED PLETED PLETED	TRACKING NUMBE	R	
DESCRIPTION  DATA RECEIVED FROM LAB DRAFT INSPECTION REPORT COM FINAL INSPECTION REPORT COM FINAL INSPECTION RPT RCD FROM FORM 3506 SENT TO EPA INSPECTION REPORT REVIEWED SAMPLES TO LAB OTHER	DATE COMPLETED PLETED PLETED	D TRACKING NUMBE		
DESCRIPTION  DATA RECEIVED FROM LAB DRAFT INSPECTION REPORT COME FINAL INSPECTION REPORT COME FINAL INSPECTION REPORT COME FORM 3506 SENT TO EPA INSPECTION REPORT REVIEWED SAMPLES TO LAB OTHER	DATE COMPLETE  PLETED PLETED M EILS	O TRACKING NUMBE		
DESCRIPTION  DATA RECEIVED FROM LAB DRAFT INSPECTION REPORT COM FINAL INSPECTION REPORT COM FINAL INSPECTION RPT RCD FROM FORM 3506 SENT TO EPA INSPECTION REPORT REVIEWED SAMPLES TO LAB OTHER	DATE COMPLETED PLETED PLETED	O TRACKING NUMBE	DATE A	GENCY/PH#
DESCRIPTION  DATA RECEIVED FROM LAB DRAFT INSPECTION REPORT COME FINAL INSPECTION REPORT COME FINAL INSPECTION RPT RCD FROM FORM 3506 SENT TO EPA INSPECTION REPORT REVIEWED SAMPLES TO LAB OTHER CONTROL OF THE PROPERT REVIEWED CONTROL OF THE PROPERT REVIE	DATE COMPLETE  PLETED PLETED M EILS	TRACKING NUMBE	DATE A	GENCY/PH#
DESCRIPTION  DATA RECEIVED FROM LAB DRAFT INSPECTION REPORT COME FINAL INSPECTION REPORT COME FINAL INSPECTION RPT RCD FROM FORM 3506 SENT TO EPA INSPECTION REPORT REVIEWED SAMPLES TO LAB OTHER CONTROL OF THE PROPERT REVIEWED CONTROL OF THE PROPERT REVIE	DATE COMPLETED PLETED MEILS SIGNATURE	<i>Y</i> 6/1	DATE AC	GENCY/PH#
DESCRIPTION  DATA RECEIVED FROM LAB DRAFT INSPECTION REPORT COME FINAL INSPECTION REPORT COME FINAL INSPECTION RPT RCD FROM FORM 3506 SENT TO EPA INSPECTION REPORT REVIEWED SAMPLES TO LAB OTHER CONTROL OF THE PROPERT REVIEWED CONTROL OF THE PROPERT REVIE	DATE COMPLETED PLETED MEILS SIGNATURE	TRACKING NUMBE	DATE AC	GENCY/PH#
DESCRIPTION  DATA RECEIVED FROM LAB DRAFT INSPECTION REPORT COME FINAL INSPECTION REPORT COME FINAL INSPECTION REPORT COME FORM 3506 SENT TO EPA INSPECTION REPORT REVIEWED SAMPLES TO LAB OTHER COTION 7: SIGNATURES NAME (PRINT)  SPECTOR 1 M. MANDIS	DATE COMPLETED PLETED MEILS SIGNATURE	<i>Y</i> 6/1	DATE AC	GENCY/PH# CY/372-797 CY/372-789

## ETF (ST-4500) Site Tour Notes (Ecology)

Ecology traveled to ETF to tour the facility 5/11/06. Process flow was explained and a diagram and drawing were distributed. Upcoming modifications to the facility were discussed before the tour including:

- Replacing the LERF Return hose line with hard-piping (stainless steel).
- Installation of a stainless steel line in ETF for direct feed into the Secondary Waste Receiving Tank (SWRT). This line will also serve as a recycle line from the LERF Wastewater Feed stream to Secondary Waste Receiving Tank (SWRT) in the Secondary Treatment Train passing through the influent filter. (Thus allowing a larger amount of dissolved solids to be removed before the wastewater is sent though the Reverse Osmosis (RO) unit in the Main Treatment Train (MTT)).

Discussion turned to Ecology's Engineering requirements for the modifications. Required notification for the piping modifications were provided during this visit. Ecology will add this Technical Assistance Report (with attached notes and drawings) in the Ecology ETF facility Water Quality file.

Also discussed was the addition of a new solidification treatment unit (STU) which will grout the solids and supplement the Thin Film Dryer. Before the installation and operation of the STU and per WAC 173-240-110, submission and approval of an Engineering Report, submission and approval of Plans and Specifications, and submission of an Operation and Maintenance Manual are required for any modification of the industrial wastewater facility. The ETF facility has requested that Ecology waive the requirement of the three step submission of documents in lieu of conceptual plans per WAC 172-240-110 (5). Ecology has agreed to the waiver of the three step process and requesting that the submittal contain:

- 1. Introduction
  - Objective of the new (STU) unit
  - Background description of current plant operation (thin film dryer)
  - Current solid waste requirements
  - Current solid waste characterization
- 2. Description of Proposed Modifications (STU)
  - Reason for modification
  - Overall effects of the unit on the facility and other units it impacts
  - Changes/Modifications required in the facility to support the STU
  - A timetable of final design and construction
  - A vicinity map showing the location of the STU
  - An engineering drawing of STU


These requirements were documented in an example report sent to the facility 5/23/06 via email. A tour of the site followed the facility modifications discussions.

During the Ecology visit, the facility was in stand-by mode, meaning that the facility was not actively treating wastewater. Ecology toured the Operations Control room first and noted that the facility had a state-of-the-art operations control program to monitor the entire facility and various properties of each unit including, but not limited to: liquid levels/flow, operational status, amperage, rotor speed, etc. Both process flow diagram and graphical views of the properties as listed above are readily accessible. The control equipment also reports equipment malfunctions and alarms. The alarm system indicates levels of concern by color. Red alarms indicate the equipment is critical and immediate attention is required. Yellow alarms indicate the equipment is important and the condition will require attention but is not time urgent. White alarms indicate that the alarm is informational. There are two operational indicators which are green and gray. Green indicators show that the equipment is either operational or running (on). Grey indicators shows that the equipment is non-operational or not running (off). LDC screens and Audible alarms are also present on the facility floor. The Control room is staffed 24-hours per day and 7-days a week.

Ecology then Aced in and entered the facility. The Primary Treatment Train comprised of influent pipes, surge tank, rough filter, UV-oxidizer, pH adjustment tank and pH adjustment chemical storage tanks, hydrogen peroxide decomposer, fine filter, degasification column, reverse osmosis feed tank and membranes, three ion-exchange columns (standard rotating and regeneration operations), and effluent pH adjustment tank. It was noted that the wastewater treated contains a very low amount of organics. Thus, the UV-oxidizer sufficiently destroys any organics present and rarely is the hydrogen peroxide and pH adjustment functions needed. However, these units are kept operational and maintained for potential use. The effluent pH adjustment unit is also maintained for future potential use; however, it is not actively utilized either. While viewing the three (3) ion-exchange (polishing) columns, it was noted that the media has lasted 12 years. However, column 1 will require new media in the near future. Also noted during the visit was the flex pipe that will be replaced with hard pipe and the approximate path/location of the LERF influent line to the STT.

Ecology then toured the Secondary Treatment Train. The Second Treatment Train consists of the secondary waste receiving tanks, distillate flash tank, heater, evaporator and boiler. The solids slurry then travels to concentrate tanks, thin film dryer and powder hopper and are packaged in the drum handling system and routed out by conveyor tray to a storage area within the facility and moved to the drum load-out facility and disposed appropriately as RCRA waste per the ETF RCRA permit. The overheads are routed through a vapor compressor and back to the heater. Energy is conserved as much as possible and the steam from the evaporator is used in the heater. Also included in the Second Train is the resin dewater system and disposal container. The drum load out facility and location of STU was then shown to Ecology and the site visit was concluded.

## **ETF Process Flow**



\* And additional Feedback Loops

